

Approval Number: 1708511
Test Report: MA6011/H



Water Regulations Advisory Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

17th August 2017

IBA Kimya Sanayi Ve Ticaret A.S.
Karamanlilar caddesi No.12,
Sincan Organize Sanayi,
Bolgesi Sincan Ankara,
06930,
Turkey

WATER REGULATIONS ADVISORY SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

COATINGS, PAINTS & LININGS - FACTORY APPLIED PIPE & FITTINGS COATINGS.

5030

'FP60 Dark Blue'. Factory applied, dark blue coloured epoxy powder coating. Apply as per manufacturer's instructions 'TDS/FP60/Rev:0' December 2014. Cure for 10 minutes@160°C. For use with water up to 85°C.

APPROVAL NUMBER: 1708511

APPROVAL HOLDER: IBA KIMYA SANAYI VE TICARET A.S.

The Scheme reserves the right to review approval.
Approval 1708511 is valid between August 2017 and August 2022

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wras.co.uk/directory

Yours faithfully

A handwritten signature in black ink, appearing to read 'Jason Furnival', written in a cursive style.

Jason Furnival
Approvals & Enquiries Manager
Water Regulations Advisory Scheme